





From: Kim Knox knox@sojpdx.com  
Subject: FW: FW: NARA Proposed new building review
Date: April 24, 2026 at 2:41 PM
To: Chris Hagerman (hagerman@bookinggroup.com) hagerman@bookinggroup.com
Cc: Sienna Shiga sshiga@hackerarchitects.com, Yi Wang ywang@hackerarchitects.com

Some good news on a Friday afternoon!

Chris – please forward this information to County and/or City as appropriate.

Cheers,



Kim Knox (she/her) | Partner & Senior Project Manager
421 SW Sixth Avenue | Suite 750 | Portland, OR 97204
c: 503-807-5177 | e: knox@sojpdx.com

From: Tyler Fuhriman <tyler@fuhrimanconsulting.com>
Sent: Friday, April 24, 2026 2:28 PM
To: Kim Knox <knox@sojpdx.com>
Subject: Fwd: FW: NARA Proposed new building review

Regards,
Tyler Fuhriman, WWS
Fuhriman Septic Design and Consulting, LLC.
tyler@fuhrimanconsulting.com
(435) 760-0717

----- Forwarded message -----

From: **JOYE Jessica * DEQ** <Jessica.JOYE@deq.oregon.gov>
Date: Fri, Apr 24, 2026 at 1:09 PM
Subject: FW: NARA Proposed new building review
To: TYLER FUHRIMAN <tyler@fuhrimanconsulting.com>

Hi Tyler,

DEQ does not object to the proposed new building and increasing the number of beds to 76 and staff to 33. Reported average daily flows indicate the usage is below 50% of the permitted maximum peak flow. The average daily sewage flow to the drainfield should be 5,000 gpd and maximum daily flow must not exceed 10,000 gpd. All setbacks must be maintained between the septic tanks/treatment units (5' min.) and drainfield (10' min). Keep all construction activities off the drainfield area. The permittee must comply with all conditions of WPCF Onsite permit #103099.

This email serves as septic sign off. Please present this information to Multnomah County Septic Staff.

Sincerely,



Jessica Joye, REHS
NW Region and Marion
Onsite Natural Resource Specialist
She/her
[4026 Fairview Industrial Dr SE](mailto:jessica.joye@deq.oregon.gov)
[Salem, OR 97302](mailto:jessica.joye@deq.oregon.gov)
503.798.8017
jessica.joye@deq.oregon.gov
www.oregon.gov/deq

WPCF-Onsite Permitting: May 14, 2025, WPCF onsite applicants and permit holders must use Your DEQ Online, a one-stop place for submitting applications, reports, paying invoices and accessing permit information. More information on how to use Your DEQ Online can be found here:

<https://www.oregon.gov/deq/permits/Pages/WPCF-inYDO.aspx>

WPCF Onsite reporting season has begun. Please anticipate longer response times through April.

From: Tyler Fuhriman <tyler@fuhrimanconsulting.com>
Sent: Wednesday, April 22, 2026 1:26 PM
To: JOYE Jessica * DEQ <Jessica.JOYE@deq.oregon.gov>
Subject: NARA Proposed new building review

Hi Jessica,

Please see the attached documents for your review regarding the proposed new building for NARA.

This project does not include any modifications or changes to the existing septic system.

Please let me know if you have any questions or need additional information.

Kind regards,

Tyler Fuhriman, WWS
Fuhriman Septic Design & Consulting
Cell: 435-760-0717
Email: tyler@fuhrimanconsulting.com
Web: www.fuhrimanconsulting.com

Project Description_NARA.pdf

